

CHARLES MUGGEO
Water Superintendent



TOWN OF MARLBOROUGH

WATER DEPARTMENT
1650 ROUTE 9W, P.O. BOX 305
MILTON, NEW YORK 12547
Tel. (845) 795-1158
Fax (845) 795-2031

November 13, 2017

RE: Bayside Development Project

To Whom May Concern,

After reviewing the Bayside Project Plans, they seem to all be in agreement with the Town of Marlborough Water Department specifications except for a few of the following items. In reviewing the service line specs for the buildings, each apartment must have their own service line connection and also have New York State approved back flow devices. Also, after reviewing plans, it states that the tapping sleeves that you are going to use on the mains are steel tapping sleeves, but you must use stainless steel tapping sleeves. Other than that I believe everything is to my approval.

You also requested some pressure readings. The water pressure and flow on 9W has a static pressure of 145 PSI and a residual pressure of 80 PSI and a GPM of 1670 and this is all off of a 12 inch main that is located on the east side of Rt. 9W. The pressure on Purdy Ave. is at 90 PSI and there is a 6 inch main running up that road. The residual pressure and GPM is unavailable. If you have any other concerns or questions, feel free to give me a call.

Yours Truly,

Charles Muggeo

Town of Marlborough Water Superintendent