

TOWN OF MARLBOROUGH
PO Box 305 Milton NY 12547
“ Heart Of the Hudson Valley Fruit Section”
MILTON, ULSTER COUNTY, NEW YORK 12547
DEPARTMENT OF BUILDINGS

TEL NO. 795-2406
FAX NO. 795-2031

THOMAS CORCORAN JR.
BUILDING INSPECTOR
CODE ENFORCER
FIRE INSPECTOR

Date: January 29, 2021

Re: Lamela Lot Line Revision

S.B.L. : 108.4-5-30.1 & 108.4-5-30.2

This letter is to verify that the building department has reviewed the Planning Board application and has concluded :

XX : The application can be presented to the Town of Marlborough Planning Board for its review.

Density is correct for both lots (HD District , Minimum 2 Acres) 
Accessory structure is at least 10 feet from property line. 

Thank You.


Thomas J. Corcoran Jr.
Building Inspector
Code Enforcement Officer