

Medenbach & Eggers

Civil Engineering and Land Surveying P.C.

4305 US Highway 209
Stone Ridge, New York
12484-5620

Barry Medenbach, P.E.
N.Y. Lic. No. 60142
N.J. Lic. No. 27646

Phone (845) 687-0047
Fax (845) 687-4783
www.mecels.com

William R. Eggers L.S.
N.Y. Lic. No. 49785

27 OCT 2021

1 of 2

Mr. Chris Brand
Chair
Town of Marlborough Planning Board
P.O. Box 305
Milton, New York 12547

RE: 39 Main Street Milton, LLC Site Plan
SBL No. 103.1-2- 44 & 45
39 Main Street, Milton, NY

Dear Chris,

In response to Patrick Hines comment letter of 20 SEPT 2021, we offer the following;

- Item 1 - The project has been submitted to the Ulster County DPW for their review.
- Item 2 - The project has been submitted to the Ulster County Planning Board and returned with a very favorable comment letter (copy herewith).
- Item 3 - The Utility Pole Islands have been Omitted.
- Item 4 - A comment letter has been issued by the Fire Department. See comments on page 2 of 2.
- Item 5 - A Stormwater Management Report is submitted herewith.
- Item 6 - A Comment Letter have been issued by the Building Department.
- Item 7 - The Building height has been revised to +/- 32'-0" and now meets Town Zoning Criteria.
- Item 8 - The Retail Level (Main Street) is at (El. +/- 156.5'). The Second Floor Level is accessible from the rear (Off-Street Parking Lot) at (El. +/- 168.5') as well as access to the Third Floor Level at (El. +/- 188.5').
- Item 9 - Main Street Parking Spaces (8) spaces with No Islands) have been delineated. Additional Off-Street Parking (41 Spaces) have been delineated on 12 Brewster Street.
- Item 10 - The Rock removal is anticipated to be removed by Hammering and we do not anticipate Blasting.

- Item 11 - Applicant hereby requests a 'Waver' from Design Standards requiring 10x20 parking space to the 9x18 area standard. We do not believe this requires a variance.
- Item 12 - Yes, after the Road (Main Street) is widened the Proposed New Curb is installed and Proposed (8) Parking Spaces are created, the appropriate traffic striping shall be applied.

The following is a response to the Milton Engine Company No. 1's comment letter of (no date on letter).

- Item 1 - A Fire Hydrant has been added (just after driveway entrance) to the Site Plan / Grading and Utility Plan.
- Item 2 - A Fire Truck Turn Model has been done to show the successful navigation onto and off the site.
- Items (3) and (4) shall be addressed by and on the project architectural drawings.

We hope this meets with your approval.

Sincerely,



Thomas Kentop, Sr.
Project Manager
Medenbach and Eggers Civil Engineering and Land Surveying PC
4305 US Hwy 209 Stone Ridge NY 12484
Phone : 845-687-0047, ext 105
thomas@mecels.com