

CHARLES MUGGEO
Water Superintendent



TOWN OF MARLBOROUGH

WATER DEPARTMENT
1650 ROUTE 9W, P.O. BOX 305
MILTON, NEW YORK 12547
Tel. (845) 795-5100 x5
Fax (845) 795-2031

September 12, 2022

Re: 132 Milton Turnpike

SBL 103.1-1-33.200

Chairman Chris Brand

Planning Board Members

Dear Mr. Brand and Planning Board Members:

I am writing this letter in regard to the subdivision on 132 Milton Turnpike. The Town of Marlborough Water district will be able to service the one house on the property, however we have a few concerns. This area is known to have low pressure issues, and only 50% of the property is actually in the Water District. If they are planning on building any other homes, they might have to look at ways to increase the pressure or find another source of water. If you have any questions or concerns please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Charles Muggeo" followed by "Wtr".

Charles Muggeo

Water Superintendent