

() RENEWAL

ULSTER COUNTY DEPARTMENT OF HEALTH
ENVIRONMENTAL HEALTH SERVICES
239 GOLDEN HILL LANE
KINGSTON, NY 12401

() FORMERLY:

PERMIT TO CONSTRUCT A WASTE DISPOSAL SYSTEM

THIS PERMIT IS ISSUED UNDER THE PROVISIONS OF ARTICLE VI, SECTION 6.4.0 OF THE
ULSTER COUNTY SANITARY CODE. PERMITS ARE NON-TRANSFERABLE.

This Permit is Valid for a *Two Year* Period – Date of Issuance: 07/26/2024

1. APPLICANT

Marlboro Property Management c/o Sam Dong

2. ADDRESS OF APPLICANT

1108 Route 9W
Marlboro, NY 12542

3. LOCATION OF PROJECT

Burma Road, Lot #2

4. TOWNSHIP

Marlborough

5. TYPE OF OWNERSHIP

Single Family - 4 bedroom

6. TAX IDENTIFICATION NUMBER

108.3-3-21.132

DESCRIPTION OF WORKS

INSTALLATION OF: System Type: In-Ground

Minimum separation of the absorption field 100 feet from well, (150 feet if seepage pit), 100 feet from a stream or water course, and 10 feet from the property line.

All systems shall be designed / constructed in conformance with all applicable rules and regulations.
(Appendix 75-A "Wastewater Treatment Standards – Individual Household Systems", latest revision and / or DEC Design Standards for Wastewater Treatment Works, latest revision.)

Well log to be submitted prior to final approval.

Well construction to be in accordance with Appendix 5-B, Standards for Water Wells, November 23, 2005.



The sewage system must be installed in accordance with the plans submitted by David Feeney and approved / accepted by this department on 07/26/2024.

A New York State Licensed P.E., Architect, or Exempt Land Surveyor must certify that the sewage system has been installed in accordance with the approved / accepted plan.

24-042

CK

2014



07/26/24

cc: NYC WATERSHED - () Ashokan, () Delaware, () Rondout/Neversink

FULLY DELEGATED ()

JOINT REVIEW AND APPROVAL ()

() RENEWAL

ULSTER COUNTY DEPARTMENT OF HEALTH
ENVIRONMENTAL HEALTH SERVICES
239 GOLDEN HILL LANE
KINGSTON, NY 12401

() FORMERLY:

PERMIT TO CONSTRUCT A WASTE DISPOSAL SYSTEM

THIS PERMIT IS ISSUED UNDER THE PROVISIONS OF ARTICLE VI, SECTION 6.4.0 OF THE
ULSTER COUNTY SANITARY CODE. PERMITS ARE NON-TRANSFERABLE.

This Permit is Valid for a *Two Year* Period – Date of Issuance: 06/21/2024

1. APPLICANT

Marlboro Property Management c/o Sam Dong

2. ADDRESS OF APPLICANT

1108 Route 9W
Marlboro, NY 12542

3. LOCATION OF PROJECT

Burma Road, Lot #3

4. TOWNSHIP

Marlborough

5. TYPE OF OWNERSHIP

Single Family - 4 bedroom

6. TAX IDENTIFICATION NUMBER

108.3-3-21.132

DESCRIPTION OF WORKS

INSTALLATION OF: System Type: In-Ground

Minimum separation of the absorption field 100 feet from well, (150 feet if seepage pit), 100 feet from a stream or water course, and 10 feet from the property line.

All systems shall be designed / constructed in conformance with all applicable rules and regulations.
(Appendix 75-A "Wastewater Treatment Standards – Individual Household Systems", latest revision and / or DEC Design Standards for Wastewater Treatment Works, latest revision.)

Well log to be submitted prior to final approval.

Well construction to be in accordance with Appendix 5-B, Standards for Water Wells, November 23, 2005.


The sewage system must be installed in accordance with the plans submitted by David Feeney and approved / accepted by this department on 06/21/2024.

A New York State Licensed P.E., Architect, or Exempt Land Surveyor must certify that the sewage system has been installed in accordance with the approved / accepted plan.

24-043

CK

2014



cc: NYC WATERSHED - () Ashokan, () Delaware, () Rondout/Neversink

FULLY DELEGATED ()



06/21/24

JOINT REVIEW AND APPROVAL ()