

Chris Kresser <ckre@co.ulster.ny.us>
To: Tom Corcoran <tcorcoran@marlboroughny.us>

Thu, Dec 19, 2024 at 8:30 AM

Tommy:

As per our field meeting on Burma Rd for lot 2 in the subdivision, the neighboring existing well is not in the direct line of drainage from the proposed septic drain field. The topography isn't direct and there is a swale on the neighboring property in between the existing well and proposed septic. This means that there needs to be at least 100 feet of separation and not 200 feet. There is 100+ feet so the permit is valid. If you have any other questions/concerns please let me know.

Christopher A. Kresser
Senior Public Health Sanitarian
Ulster County Department of Health
Environmental Health Services Division
Golden Hill Office Building
239 Golden Hill Lane
Kingston, NY 12401
Phone: (845)340-3016
Fax: (845)340-3045
Email: ckre@co.ulster.ny.us